

OPBRENGSTVERGELIJKING 10 KwP 2013 (Twente vs Texel)

Merk / Locatie	Techniek	Vermogen	Locatie	Helling	JAN	FEB	MRT	APR	MEI	JUN	JUL	AUG	SEP	OKT	NOV	DEC	Totaal
SHARP Twente	Poly-si	245 watt	Twente	30°	66	347	729	1093	1170	1342	1341	1336	851	652	254		9181
LG Twente	Mono-si	245 watt	Twente	30°	65	339	706	1085	1154	1326	1324	1326	848	649	250		9072
SHARP Twente	Micro-Si	128 watt	Twente	15°	64	311	674	1021	1159	1359	1366	1323	773	536	196		8782
Solar Frontier Twente	CIS	155 watt	Twente	30°	90	375	800	1173	1265	1458	1467	1474	934	717	281		10034
SHARP Texel	Poly-si	245 watt	Texel	19°	279	380	939	1478	1469	1409	1540	1453	916	588	297		10748
LG Texel	Mono-si	245 watt	Texel	19°	287	389	950	1493	1481	1418	1545	1452	921	597	305		10838
SHARP Texel	Micro-Si	128 watt	Texel	19°	245	348	870	1420	1446	1401	1562	1470	902	556	264		10484
Solar Frontier Texel	CIS	155 watt	Texel	19°	299	409	1015	1633	1637	1585	1745	1639	1027	656	324		11969

