



# Disclaimers

## Important Notice

Copyright © SolarEdge Inc. All rights reserved.

No part of this document may be reproduced, stored in a retrieval system or transmitted, in any form or by any means, electronic, mechanical, photographic, magnetic, or otherwise, without the prior written permission of SolarEdge Inc.

The material furnished in this document is believed to be accurate and reliable. However, SolarEdge Inc. assumes no responsibility for the use of this material. SolarEdge reserves the right to make changes to this material at any time and without notice. You may refer to the SolarEdge website ([www.solaredge.com](http://www.solaredge.com)) for the most updated version.

All company and brand products and service names are trademarks or registered trademarks of their respective holders.

Patent marking notice: <http://www.solaredge.us/groups/patent>

## Exclusion of Liability

The general terms and conditions of delivery of SolarEdge apply.

The content of these documents is continually reviewed and amended, where necessary. However, discrepancies cannot be excluded. No guarantee is made for the completeness of these documents.

## FCC Compliance

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment OFF and ON, you are encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and the receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

Changes or modifications not expressly approved by the party responsible for compliance may void the user's authority to operate the equipment.

# Support and Contact Information

If you have technical queries concerning our products, please contact us:

Australia	1800 465 567	<a href="mailto:support@solaredge.net">support@solaredge.net</a> <a href="mailto:o:australianfo@solaredge.com">o:australianfo@solaredge.com</a>
APAC (Asia Pacific)		<a href="mailto:support@asia.solaredge.com">support@asia.solaredge.com</a>
Belgium	080073041	<a href="mailto:support@solaredge.be">support@solaredge.be</a>
France	0800917410	<a href="mailto:support@solaredge.fr">support@solaredge.fr</a>
Germany	+49 89 5459730	<a href="mailto:support@solaredge.de">support@solaredge.de</a>
Italy	800 784 824	<a href="mailto:support@solaredge.it">support@solaredge.it</a>
Japan	+81.3.5530.9360	<a href="mailto:support@solaredge.jp">support@solaredge.jp</a>
United Kingdom	0800 028 1183	<a href="mailto:support@solaredge.uk">support@solaredge.uk</a>
US & Canada	1 877 360 5292	<a href="mailto:ussupport@solaredge.com">ussupport@solaredge.com</a>
Greece	00800125574	
Israel	+972 73 2403118	
Netherlands	08000221089	
Worldwide	+972 73 240118	
Fax	+972 73 240117	

Before contacting, make sure to have the following information at hand:

- Model and serial number of the product in question
- The error indicated on the inverter screen or on the SolarEdge monitoring portal if there is such an indication.
- System configuration information, including the type and number of modules connected and the number and length of strings.
- The communication method to the SolarEdge monitoring portal if the site is connected

# Table of Contents

<b>Disclaimers</b> .....	<b>1</b>
Important Notice.....	1
Exclusion of Liability.....	1
FCC Compliance.....	1
<b>Support and Contact Information</b> .....	<b>2</b>
<b>Table of Contents</b> .....	<b>3</b>
<b>Chapter 1: Safety</b> .....	<b>4</b>
SAFETY SYMBOLS.....	4
SAFETY INSTRUCTIONS.....	4
<b>Chapter 2: Introducing the SolarEdge Power Optimizers</b> .....	<b>7</b>
<b>Chapter 3: Power Optimizer Installation</b> .....	<b>8</b>
Site Installation General Workflow.....	8
Planning the Power Optimizers Installation.....	10
Planning Connection to SolarEdge Inverters.....	10
Planning Connection to SolarEdge inverters (with or without Safety & Monitoring Interface).....	11
Installation Equipment List.....	11
Package Contents.....	12
Installing the Power Optimizer.....	12
Step 1, Mounting and Grounding the Power Optimizers.....	12
Step 2, Connecting a Module to a Power Optimizer.....	14
Step 3, Connecting Power Optimizers in Strings.....	14
Step 4, Providing Installation Information.....	15
Step 5, Verifying Proper Power Optimizer Connection.....	15
Step 6, Disabling SafeDC™ (Only when Connecting to Non-SolarEdge Inverters without SMI)	16
Step 7, Commissioning.....	17
<b>Appendix A: Troubleshooting</b> .....	<b>18</b>
For Installations with SolarEdge Inverters.....	18
For Installations with Non-SolarEdge Inverters.....	19

# Chapter 1: Safety

During installation, testing and inspection adherence to all the handling and safety instructions is mandatory.

## SAFETY SYMBOLS

The following safety symbols are used in this document. Familiarize yourself with their symbols and their meaning before installing or operating the system.



### WARNING!

Denotes a hazard. It calls attention to a procedure that, if not correctly performed or adhered to, could result in **injury or loss of life**. Do not proceed beyond a warning note until the indicated conditions are fully understood and met.

*Dénote un risque: il attire l'attention sur une opération qui, si elle n'est pas faite ou suivie correctement, pourrait causer des blessures ou un danger de mort. Ne pas dépasser une telle note avant que les conditions requises soient totalement comprises et accomplies.*



### CAUTION:

Denotes a hazard. It calls attention to a procedure that, if not correctly performed or adhered to, could result in **damage or destruction of the product**. Do not proceed beyond a caution sign until the indicated conditions are fully understood and met.

*Dénote un risque: il attire l'attention sur une opération qui, si elle n'est pas faite ou suivie correctement, pourrait causer un dommage ou destruction de l'équipement. Ne pas dépasser une telle note avant que les conditions requises soient totalement comprises et accomplies.*



### NOTE:

Denotes additional information about the current subject.



### IMPORTANT SAFETY FEATURE:

Denotes information about safety issues.

## SAFETY INSTRUCTIONS

The following notes and warnings apply when installing the power optimizers:



### WARNING:

When modifying an existing installation, turn OFF the inverter ON/OFF switch, the AC/DC Safety Switch and the AC switch of the main circuit board.

*Avant de faire ces étapes, éteignez l'onduleur monophasé en mettant sur OFF l'interrupteur ON/OFF situé au bas de l'onduleur.*



### WARNING

Input and output connectors are not watertight until mated. Open connectors should be mated to each other or plugged with appropriate watertight caps.

*Les connecteurs d'entrée et sortie ne sont pas étanches jusqu'à ce qu'ils soient accouplés. Les connecteurs doivent être accouplés ou fermés avec des terminaux étanches.*



### CAUTION:

This unit must be operated according to the operating specifications in this document.

*Cette unité doit être opérée suivant les instructions trouvées dans ce document.*



### CAUTION:

Cutting the power optimizer input or output cable connector is prohibited and will void the warranty.

*Sectionner les câbles d'entrées ou de sortie de l'optimiseur est interdit et annule sa garantie.*

**CAUTION:**

Choose a mounting location where optimizers will not be submerged in water.

*Choisissez le lieu de montage tel que l'optimiseur ne puisse pas être submergé par l'eau.*

**CAUTION:**

If you intend to mount the optimizers directly to the module or module frame, first consult the module manufacturer for guidance regarding the mounting location and the impact, if any, on module warranty. Drilling holes in the module frame should be done according to the module manufacturer instructions.

*Pour installation à même le module ou la monture du module, consultez d'abord le fabricant du module sur la position et son impact sur la garantie du module. Le perçage de trous dans le cadre du module devra se faire suivant les instructions du fabricant.*

**CAUTION:**

Installing a SolarEdge system without ensuring compatibility of the module connectors with the optimizer connectors may be unsafe and could cause functionality problems such as ground faults, resulting in inverter shut down.

In order to ensure mechanical compatibility of the SolarEdge optimizers and the modules to which they are connected:

- Use identical connectors from the same manufacturer and of the same type on both the power optimizers and on the modules; or
- Verify that the connectors are compatible in the following way:
  - The connector manufacturer should explicitly verify compatibility with the SolarEdge optimizer connector; and
  - A third-party test report by one of the listed external labs (TUV, VDE, Bureau Veritas UL, CSA, InterTek) should be obtained, verifying the compatibility of the connectors.

*Les connecteurs du module doivent être mécaniquement compatibles avec les optimiseurs de puissance. Sinon, le système SolarEdge installé peut être dangereux ou causer des problèmes fonctionnels, tels que les défauts de terre, qui peuvent provoquer un arrêt de l'onduleur.*

*Afin d'assurer la compatibilité mécanique entre les optimiseurs de puissance SolarEdge et les modules auxquels ils sont connectés, il faut :*

- Utiliser des connecteurs identiques du même fabricant et du même type aussi bien pour les optimiseurs de puissance que pour les modules.
- Vérifiez que les connecteurs sont compatibles de la manière suivante:
  - Le fabricant du connecteur doit explicitement vérifier la compatibilité avec le connecteur SolarEdge.
  - Un rapport de test de tierce partie doit être effectué par l'un des laboratoires externes indiqués ci-dessous:(TUV, VDE, Bureau Veritas UL, CSA,Intertek), qui vérifiera la compatibilité des connecteurs.


**NOTE:**

All modules in the same installation **must** be equipped with power optimizers.

**NOTE:**

The maximum installation altitude is 4000m / 13124 ft.

**NOTE:**

The  symbol appears at grounding points on the SolarEdge equipment. This symbol is also used in this manual.



**IMPORTANT SAFETY FEATURE:**

Each power optimizer is equipped with a SafeDC mechanism which ensures the optimizer outputs a safe 1V voltage until connected to the SolarEdge inverter or SMI, and the inverter/SMI are turned ON.

When connecting the power optimizers to a non-SolarEdge inverter without a Safety and monitoring Interface, you must disable the SafeDC before connecting to the inverter. Refer to the *SolarEdge Key manual* for more information on how to disable the SafeDC

After disabling the SafeDC, opatimizers will always output the module voltage regardless of inverter state.

The following table summarizes the safety considerations when using the power optimizers:

DC Mode	With SolarEdge inverter	With non-SolarEdge inverter, with SMI	With non-SolarEdge inverter, without SMI
Safe DC - 1V	<ul style="list-style-type: none"> <li>▪ Optimizer is not connected, or</li> <li>▪ AC is OFF, or</li> <li>▪ The inverter ON/OFF switch is turned OFF.</li> </ul>	<ul style="list-style-type: none"> <li>▪ Optimizer is not connected, or</li> <li>▪ AC is OFF, or</li> <li>▪ The inverter ON/OFF switch is turned OFF.</li> </ul>	Never
PV Module Voltage	Inverter is ON	SMI is ON	Always

## Chapter 2: Introducing the SolarEdge Power Optimizers

SolarEdge power optimizers are DC converters connected to PV modules in order to maximize power harvesting by performing Maximum Power Point Tracking (MPPT) at the module level.

Power optimizers with SolarEdge's new IndOP™ (Independent Optimization) technology operate without additional hardware interface and work directly with the SolarEdge inverter as well as with the broad range of SolarEdge inverter optimizers with MPN starting with "OPJ" or "Pxxx" have the IndOP feature.

Each power optimizer transmits its module's performance data over the DC power line. When using a SolarEdge inverter, these signals are received by the inverter and can be used for maintenance and remote monitoring. To monitor the modules when using SolarEdge inverters, add a SolarEdge Safety and monitoring interface device (purchased separately). Monitoring the optimizers is not mandatory for generating power.




# Chapter 3: Power Optimizer Installation


## Site Installation General Workflow

The following is the workflow for installing and setting up a **using a SolarEdge inverter or a non SolarEdge one (with or without SMI)**. Most of these procedures can also be **used for an existing site.**This manual describes only the power optimizer installation.


### Installing with Non-SolarEdge Inverter With SMI



### Installing with Non-SolarEdge Inverter Without SMI



### Installing with SolarEdge Inverter



## Planning the Power Optimizers Installation

Plan the installation according to the inverters to be used. The following sections describe the planning considerations when using SolarEdge inverters, and when using other SolarEdge inverters, with or without the Safety & Monitoring Interface.

### Planning Connection to SolarEdge Inverters

- You can create parallel strings of unequal length, that is, the number of power optimizers in each string does not have to be the same.
- Use the minimum and maximum string lengths, depending on the inverter string lengths are specified in the *Power Optimizer Datasheets* supplied with the power optimizer. Refer to the SolarEdge Site Designer for string length verification.
- Completely shaded modules cause their power optimizers to temporarily shut down. This will affect the performance of the other power optimizers in the string as long as the minimum number of power optimizers connected to unshaded modules meet the minimum required string length under typical conditions fewer than the minimum number of optimizers connected to unshaded modules, add more optimizers to the string.
- Refer to the SolarEdge Site Designer for verification. You can download the software from <http://www.solaredge.com/support/downloads>




Figure 1: Power Optimizers Connected in Series to SolarEdge Inverter


## Planning Connection to non-SolarEdge inverters (with or without Safety & Monitoring Interface)

- Refer to the inverter manual and manufacturer's data sheets.
- Use the non-SolarEdge inverter design rules, referring to the PV modules as installed without optimization.




### WARNING!

Designing strings that are not according to the inverter design rules may result in permanent damage to the inverter.



**Figure 2: Power optimizers connected in series to a non-SolarEdge inverter via Safety & Monitoring Interface**



**Figure 3: Power optimizers connected in series directly to a non-SolarEdge inverter**

## Installation Equipment List

Standard tools can be used during the installation of the power optimizer. The following is a recommendation of the equipment to be used:

- Drilling machine and bits suitable for the surface on which the optimizer will be installed
- 1/4" or 5/16" screws, springs and washers for attaching the power optimizer to the racking
- Screwdriver
- Voltmeter
- When installing a non-SolarEdge inverter without SolarEdge Key

## Package Contents

- Poweroptimizers
- Datasheet
- This manual
- Grounding washers (North America only)

## Installing the Power Optimizer

### Step 1, Mounting and Grounding the Power Optimizers

- 1 Use the power optimizer mounting brackets to attach the power optimizer to the racking described below
- 2 Determine the power optimizer mounting location.
- 3 If required mark all mounting hole locations and the holes.



**CAUTION:**  
Do not drill through the power optimizer or through the mounting holes. The drilling vibrations can damage the power optimizer and will void the warranty.  
*Ne pas percer à travers la optimiseur de puissance ou ses trous de fixation. Les vibrations qui en résulteraient peuvent endommager la optimiseur de puissance.*

- 4 Attach power optimizer to the racking using the 5/16" or 1/4" screws and washers.
- 5 **For North America only** - use the following methods to ground the power optimizer:
  - **For mounting on a grounded metal rail:** Use the provided 5/16" stainless steel star washer between the railing and the flat side of the mounting bracket. The grounding washer should be through the anodize coating of the railing to ensure a positive connection. Apply torque of 9.5 N\*m / 7 lb\*ft.





Figure 4: Power optimizer grounding using the star washer

- For mounting on rails with sliding nut fasteners, or on an un-grounded structure (such as a wooden structure), connect an equipment grounding conductor to the grounding terminal according to the supplied instructions (the terminal should be purchased separately). The grounding terminal accepts a wire of #4 AWG, and must be sized for equipment grounding per NEC 250.122 requirements. Tighten the screws connecting the power optimizer to the frame and the grounding terminal screw. Apply torque of 9.5 N\*m / 7 lb\*ft.

**WARNING:**

The metallic enclosure of the power optimizer must be grounded in accordance with the requirements of the Local and National Codes.

*L'enceinte métallique de l'optimiseur de puissance doit être mise à la terre en accord avec les réglementations locales et nationales..*



**Figure 5: Power optimizer grounding terminal**

- For rest of the world power optimizers, use double insulated and grounding is not required.

**NOTE:**

Record power optimizer serial numbers and locations, as described in *Step 4, Providing Installation Information* on page 15.

- 6 Verify that each power optimizer is securely attached.

\* For additional information, refer to <http://www.solaredge.com/files/pdf/duct/Updatedcdc-grounding.pdf>

## Step 2, Connecting a Module to a Power Optimizer

Connect the Plus (+) output connector of the module to the Plus (+) input connector of the power optimizer. Connect the minus (-) output connector of the module to the minus (-) input connector of the power optimizer.



**WARNING!**

Verify that you have identified the inputs correctly. The power optimizer input cables are the short ones. Do not connect modules to power optimizer outputs.




Figure 6: Power optimizer connectors

## Step 3, Connecting Power Optimizers in Strings

**► To connect a string of modules:**

- 1 Connect the minus (-) output connector of the string's first power optimizer to the Plus (+) output connector of the string's second power optimizer.
- 2 Connect the rest of the power optimizers in the string the same way.
- 3 While the modules are exposed to sunlight, verify polarity by measuring the string polarity with a voltmeter.




Figure 7: Power optimizers connected in series

- 4 Connect to the inverter according to the installation plan (see the *Power Optimizers Installation* on page 40).

**NOTE:**

When the installation is done with SMI, the cable length between power optimizers and the SMI should not exceed 150m.

## Step 4, Providing Installation Information

If you intend to monitor the installation using the SolarEdge portal, it is recommended to record the physical location of each power optimizer. Use the following methods for information.

### Paper Template

Fill out the Physical Layout Template using the detachable 2D barcode stickers on each power optimizer. Once the form is completed, scan it and upload the scanned file to the SolarEdge portal during site registration. For an example paper template, refer to [www.solaredge.com/files/pdfs/physical-layout-template.pdf](http://www.solaredge.com/files/pdfs/physical-layout-template.pdf).

For detailed information, refer to the *SolarEdge Site Mapping Template Application Note*, available on the SolarEdge website at [http://www.solaredge.com/files/pdfs/application\\_note\\_using\\_site\\_mapping\\_template.pdf](http://www.solaredge.com/files/pdfs/application_note_using_site_mapping_template.pdf).

### iPhone Site Mapper

Use the SolarEdge Site Mapper iPhone application to scan the power optimizer 2D barcodes. It then creates a file that can be uploaded to the SolarEdge portal during site registration. The SolarEdge Site Mapper can be downloaded from the Apple iTunes Store.

For detailed information, refer to the *SolarEdge Site Mapper Software Guide* or to the *Site Mapper demo movie*, available on the SolarEdge website at [www.solaredge.com/groups/install/site\\_mapper](http://www.solaredge.com/groups/install/site_mapper).

## Step 5, Verifying Proper Power Optimizer Connection

After a module is connected to a power optimizer, the power optimizer outputs a safe voltage of 1V. Therefore, the total string voltage should be equal to 1V times the number of power optimizers connected in series in the string. For example, if 10 power optimizers are connected in a string, then 10V should be produced.

- 1 Measure the voltage of each string individually before connecting to the other strings or to the AC/DC Safety Switch.
- 2 Use a voltmeter with at least 0.1V measurement accuracy.
- 3 Make sure the modules are exposed to sunlight during the test. Otherwise, the power optimizers may not be powered. If you use a tracker, the power optimizer will turn ON only if the tracker is tracking the sun and at least 2W are provided by the module.



# Step 6, Disabling SafeDC™ (Only when Connecting to Non-SolarEdge Inverters without SMI)



**WARNING!**  
In installations with SolarEdge Inverters or with SMI, make sure that the SafeDC™ is enabled for all the power optimizers.



**NOTE:**  
This section is relevant only when connecting power optimizers to a non-SolarEdge inverter and **not** using the SolarEdge Safety & Monitoring Interface.

SolarEdge power optimizers are provided in a SafeDC mode: when connected to a PV module these power optimizers will output a safe voltage of 1VDC until they are paired either with a SolarEdge inverter or the SolarEdge Safety & Monitoring Interface and power production has started.

When connecting power optimizers directly to a non-SolarEdge inverter without a Safety and monitoring interface disabling the SafeDC mode is required using the SolarEdge Key product. For more information refer to the *SolarEdge Key User Manual* available on the SolarEdge website at <http://www.solaredge.com/groups/support/downloads>.




Figure 8: The SolarEdge Key

**To disable the SafeDC mode:**

- 1 Press the ON/OFF button (⏻) to turn the SolarEdge Key ON. The message appears on the SolarEdge Key LCD. XXX is the receiving voltage measurement.



**NOTE:**  
Only one string of power optimizers can be connected to a SolarEdge Key (4-30 power optimizers).

- 2 Connect the Plus (+) connector of the string of optimizers to the Plus (+) input connector of the SolarEdge Key. Connect the Minus (-) output connector of the string of optimizers to the Minus (-) input connector of the SolarEdge Key (Figure 9).

- 3 Disable the SafeDC (refer to the SolarEdge Key User Manual (<http://www.solaredge.com/groups/support/downloads>)). The SafeDC mode is now disabled and the voltage of each power optimizer equals the voltage of the module ( $V_{oc}$ ).

**WARNING:**

The DC cables carry a high voltage and the power optimizers no longer output a safe 1V output. PROCEED WITH CARE!

- 4 Disconnect the string cables connected with commissioning.




Figure 9: SolarEdge Key connection


## Step 7, Commissioning

Connect the strings to the inverter

- When connecting SolarEdge inverters, or to SolarEdge inverters with SM, perform the Commissioning steps as described in the *SolarEdge Inverter Installation Manual*, or *SolarEdge SMI Installation Manual*, available on the SolarEdge website at <http://www.solaredge.com/groups/support/downloads>. All the power optimizers must be logically paired to the inverter. The power optimizers do not start producing power until they are paired with an inverter.
- When connecting to SolarEdge inverters without SM, this is not required. Perform the Commissioning steps of the non-SolarEdge inverter as described in its manual.

# Appendix A: Troubleshooting

## For Installations with SolarEdge Inverters

Problem	Possible Cause	Possible Solution
String voltage is OV	Output of one or more power optimizers is disconnected	Connect all power optimizer outputs
String voltage not OV but lower than no. of optimizers	One or more of the power optimizers are not connected in the string	Connect all power optimizers
	One or more of the modules are not connected properly to their power optimizer inputs	Connect the modules to the optimizer inputs
	Wrong polarity connection of one of the strings	Check polarity of the string output with a voltmeter and correct if needed.
<p>String voltage higher than the number of optimizers</p> <div style="border: 1px solid black; padding: 5px;">  <p><b>WARNING!</b></p> <p>If the measured voltage is too high, the installation may not have a safe low voltage. <b>PROCEED WITH CARE!</b> A deviation of <math>\pm 1\%</math> per string is reasonable.</p> <p><i>Si la tension mesurée est trop haute, la tension basse de sécurité pourrait manquer dans l'installation. REDOUBLEZ DE PRECAUTION.</i></p> <p><i>Une déviation de <math>\pm 1\%</math> par string est raisonnable.</i></p> </div>	An extra power optimizer is connected in the string	Check if an extra power optimizer is connected in the string. If <del>proceed</del> proceed to next solution.
	A module is connected directly to the string, without a power optimizer.	Verify that only power optimizers are connected in the string and that no module outputs are connected without a power optimizer. If the problem persists, proceed to the next step.
	A malfunction of one of the power optimizers	<ul style="list-style-type: none"> <li>• Disconnect the wires that connect the power optimizers in the string</li> <li>• Measure the output voltage of each power optimizer in order to locate the power optimizer that does not output the 1V safety voltage.</li> <li>• If a malfunctioning power optimizer is located, check its connections, polarity, module voltage.</li> <li>• If a malfunction cannot be bypassed or resolved, skip the malfunctioning power optimizer thus connecting a shorter string</li> <li>• Do not continue before finding the problem and replacing the malfunctioning power optimizer</li> </ul>
	SafeDC mode was disabled using the SolarEdge Key	Enable the SafeDC.

## For Installations with Non-SolarEdge Inverters

Problem	Possible Cause	Diagnostics/Possible Solution
String voltage is 0V	Output of one or more power optimizers is disconnected	Check/connect all power optimizer outputs
	PV Modules are connected to power optimizers with reversed polarity	Check the PV module polarity using a voltmeter, and correct if needed
	Fuse is blown / DC circuit breaker is disconnected	Replace the fuse, or connect DC circuit breaker. The Fuse/Circuit breaker should support current of 15A or higher
String voltage is lower than minimum input voltage of the inverter	Insufficient number of modules in the string	Verify that the number of modules connected in the string is according to the inverter's design rules. Refer to the Inverter Manual or PV module datasheets to determine minimum string length
	One or more of the power optimizers are not connected to the string	For installation with safety & monitoring interface: <ol style="list-style-type: none"> <li>1. Turn OFF the SMI</li> <li>2. Wait ~30sec until all optimizers are in SafeDC mode</li> <li>3. Measure the string output using a voltmeter</li> <li>4. If the string output is less than the number of optimizers, check and/or connect all power optimizers</li> <li>5. Conduct pairing</li> </ol>
		For installations without safety & monitoring interface: check / connect all power optimizers
	Wrong polarity connection on one of the strings	Check polarity of the string output using a voltmeter and correct if needed.
	One or more of the modules are not connected properly to the power optimizer inputs	For installation with safety & monitoring interface: <ol style="list-style-type: none"> <li>1. Turn OFF the SMI</li> <li>2. Wait ~30sec until all optimizers are in SafeDC mode</li> <li>3. Measure the string output using a voltmeter</li> </ol>

Problem	Possible Cause	Diagnostics/Possible Solution
	<p>One or more power optimizer have SafeDC enabled</p>	<p>4. If the string output is less than the number of optimizers, check and/or connect all power optimizers</p> <ul style="list-style-type: none"> <li>• For installation with safety &amp; monitoring interface, conduct pairing (refer to the SMI manual)</li> <li>• For installations without safety &amp; monitoring interface, use the SolarEdge Key to disable SafeDC</li> </ul>
<p>String voltage is higher than the maximum range of the inverter.</p>	<p>The number of PV modules is above the maximum string size allowed by the inverter.</p>	<p>Verify that the number of modules connected in the string is according to the inverter design rules. Refer to the inverter manual or module datasheet to determine the maximum string length</p>
<p>The inverter is not waking up</p>	<p>The inverter voltage is below wakeup voltage</p>	<p>Refer to inverter manual or module datasheet to determine the minimum string length</p>

If you have technical queries concerning our products, please contact our support through SolarEdge service portal:  
<http://www.solaredge.com/groups/support/services>

North America	(Toll free) 1877 360 529 2
Australia	(Toll free) 1800 46 55 67
Germany	089 454 597 30
France	(Toll free) 0800 917 410
Italy	(Toll free) 800 784 824
Japan	(Toll free) 81 3 5530 9360
United Kingdom	(Toll free) 0800 028 1183
Belgium	(Toll free) 0800 730 41
Israel	073 240 311 8
Rest of world	972 (0) 73 240 311 8
Fax	972 (0) 73 240 311 7
Email to:	<a href="mailto:support@solaredge.com">support@solaredge.com</a>

[www.solaredge.com](http://www.solaredge.com)

**solar**edge  
architects of energy™



MAN-01-00112-1.2